

B/MPP-1001-2004-15,000 Forms

346  
Form, 88

in replying please quote No. S. K. Haffizulla Marg, B. W. Nagar, Mumbai - 400 008.

Ex. Eng. Wdg. Proposal (1/11/11)  
E. Ward, Municipal Office, B. W. Nagar,  
Mumbai - 400 008.

**Intimation of Disapproval under Section 346 of the Mumbai  
Municipal Corporation Act, as amended up to date.**

-----EB/6768/FN/A

No. B.B./CE/ BS/A of 200 - 200

## MEMORANDUM

M/s. Trinaarti Sura Villa Developers LLP  
E-1, Mary land Apartment, D.K. Sandu  
Marg, Sandhuvadi, Chembur, Mumbai  
400071

Municipal Office,  
Mumbai 19/6/13 2013

With reference to your Notice, letter No. 200 dated 29.12.2012 and delivered on 11.1.13 and the plans, Sections Specifications and Description and further particulars and details of your buildings at C.S.No.335/10 of Matunga Division, Plot No. 129 of Laxmi Mahal Estate, Shauji Road, Matunga, Mumbai. I have to inform you that I cannot approve of the building or work proposed to be erected or executed, and I therefore hereby formally intimate to you, under Section 346 of the Bombay Municipal Corporation Act as amended upto-date, my disapproval by thereof reasons :-

**AT THAT THE FOLLOWING CONDITIONS TO BE COMPLIED WITH BEFORE  
COMMENCEMENT OF THE WORK UPTO PLINTH LEVEL.**

1. That the commencement certificate under Section 44/69(1)(a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
2. That the builder / developer / owner shall not prepare a "debris management plan" showing the prospective quantum of debris likely to be generated, arrangements for its proper storage at the site, transportation plan of the agency appointed for the same, with numbers and registration numbers of vehicles to be deployed and the final destination where the debris would be unloaded by them and submit the same to the Zonal Executive Engineer of S.W.M. Department and the same shall not be got approved before demolition of existing building or commencing any construction activity.
3. That the compound wall is not constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C. Regulation No.38(27).

( ) That proper gutters and down pipes are not intended to be put to prevent water dripping from the eaves of the roof on the public street.

( ) That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the 13<sup>th</sup> day of June 2012, but not so as to contravene any of the provision of the said Act as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time in force.

Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval

*Pruthi*  
9.6.12  
Executive Engineer, Building Proposals,  
Zone, City-11 Words.

### SPECIAL INSTRUCTIONS

(1) THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.

(2) Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 345 of the said Act.

(3) Under Byelaw No. 8 of the Commissioner has fixed the following levels :-

Every person who shall erect as new domestic building shall cause the same to be built so that every part of the drain from such building can be connected with the sewer than existing or there after to be laid in such street

(a) Not less than 2 feet (60 cms.) above the centre of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or there after to be laid in such street

(b) Not less than 2 feet (60 cms.) above every portion of the ground within 5 feet (160 cms.) of such building

(c) Not less than 92 ft. ( ) meters above Town Hall Datum.

(4) Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Municipal Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion or occupation is detected by the Assessor and Collector's Department.

(5) Your attention is further drawn to the provision of Section 353-A about the necessity of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and grant a permission before occupation and to levy penalty for non-compliance under Section 471 if necessary.

(6) Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.

(7) One more copy of the block plan should be submitted for the Collector, Mumbai Suburban District

(8) Necessary permission for Non-agricultural use of the land shall be obtained from the Collector, Mumbai Suburban District before the work is started. The Non-agricultural assessment shall be paid at the site that may be levied by the Collector, under the Land Revenue Code and Rules thereunder.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.

4. That the low lying plot will not be filled up to a reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc. and will not be leveled, rolled, consolidated and sloped towards road side, before starting the work.
5. That the structural engineer will not be appointed. Supervision memo as per Appendix-XI [Regulation 5(3) (x)] will not be submitted by him.
6. That the structural design and calculations for the proposed work accounting for seismic analysis as per relevant I.S. Code and for existing building showing adequacy thereof to take up additional load alongwith bearing capacity of the soil strata will not be submitted before C.C.
7. That the sanitary arrangements shall not be carried out as per Municipal Specifications, and drainage layout will not be submitted before C.C.
8. That the Indemnity Bond indemnifying the Corporation for damages, risks, accidents, to the occupiers and an Undertaking regarding no nuisance will not be submitted before C.C./starting the work.
9. That the existing structure proposed to be demolished will not be demolished or necessary Phase Programme with agreement will not be submitted and got approved before C.C.
10. That the qualified/Registered Site supervisor through Architect/Structural Engineer will not be appointed before applying for C.C. No
11. That All Dues Clearance Certificate from A.E.W.W. 'F/N' Ward shall not be submitted before issue of C.C.
12. That the premium/deposits as follows will not be paid -
  - a. Condonation of deficient open spaces.
  - b. Staircase / Lift area benefit.
  - c. Development charges as per M.R. & T.P. (Amendment) Act, 1992
  - d. Insecticide charges.
  - e. Payment of advance for providing treatment of construction site to prevent epidemic like dengue, malaria etc. to insecticide charges Ward.
  - f. Additional Development Cess
  - g. Labour Welfare Cess
  - h. Extra Water & Sewerage Charges
  - i. That the balance premium towards sale fungible B.U.A. shall be paid & plans shall be go amended.
13. That the extra ground rent / penalty, premium for breaches in lease, if any will not be paid to Asstt. Commissioner (Estates) office and N.O.C. from Asst. Commissioner (Estates) thereof will not be submitted to this office before C.C.
14. That the registered undertaking in prescribed proforma agreeing to demolish the excess area if constructed beyond permissible F.S.I., shall not be submitted before asking for C.C.

15. That the work will not be carried out strictly as per approved plan and in conformity with the D.C.Regulations in force;
16. That the N.O.C. from Tree authority shall not be submitted before asking for plinth C.C.
17. That the Registered Undertaking shall not be submitted for agreeing to pay the difference in premium paid and calculated as per revised land rates.
18. That the Janata Insurance policy or policy to cover the compensation claims arising out of Workmen's Compensation Act, 1923 will not be taken out and a copy of the same will not be submitted before asking C.C. and renewed during the construction of work.
19. That the N.O.C. from Asstt. Commissioner (Estates) shall not be submitted.
20. That the N.O.C. from B.E.S.T. for sub station shall not be submitted.
21. That the fresh Tax Clearance Certificate from A.A. & C 'R/N' Ward shall not be submitted.
22. That the Regd. U/T against misuse of part terrace / stilt shall not be submitted.
23. That the footpath in front of plot shall not be repaired / restored once in a year or before occupation whichever is earlier.
24. That the Indemnity bond against no nuisance due to contravening toilets shall not be submitted.
25. That the Indemnity Bond indemnifying M.C.G.M. against disputes, litigations, claims, arising out of ownership of plot shall not be submitted.
26. That the remarks from H.E. Department shall not be submitted.
27. That the debris shall not be dumped on the Municipal ground only.
28. That the board displaying the details of development of the work shall not be displayed at site.
29. That the Regd. U/T for apprising the prospective buyers regarding contravening toilets shall not be submitted before C.C.
30. That the copy of PAN card of the applicant shall not be submitted before C.C.
31. That the precautionary measures to avoid dust nuisance such as erection of G.I. sheet screens at plot boundaries upto reasonable height shall not be provided before demolition of existing structures at site.

32. That the fresh P.R. Card in the name of owner shall not be submitted before O.C.
33. That the construction activity for work of necessary piling shall not be carried out by employing modern techniques such as rotary drilling, micropiling etc. Instead of conventional Jack and hammer to avoid nuisance damage to adjoining buildings.
34. That the N.O.C. from MHADA shall not be submitted before O.C.
35. That Regd. U/T for ~~minimum Nuisance during construction~~ activity shall not be submitted before G.C.
36. That the work shall not be carried out between 7.00 A.M. to 7.00 P.M. only.
37. That the G.I. Sheet screens at plot boundaries upto adequate height to avoid dust nuisance shall not be provided before demolition of existing building.
38. That the precautionary measures to avoid nuisance due to dust, such as providing G.I. Sheets at plot boundaries up to reasonable height shall not be taken.
39. That the C.C. shall not be asked unless payment of advance for providing treatment at construction site to prevent epidemics like Dengue, Malaria, etc. is made to the Insecticide Officer of the concerned Ward Office and provision shall be made as and when required by Insecticide Officer for inspection of water tanks by providing safe and stable ladder, etc. and requirements as communicated by the Insecticide Officer shall be complied with.
40. No main beam in a R.C.C. framed structure shall not be less than 230 mm wide. The size of the columns shall also not be governed as per the applicable I.S. codes.
41. All the cantilevers (Projections) shall not be designed for five times the load as per IS Code 1993-2002 including the columns projecting beyond the terrace and carrying the overhead water storage tank, etc.
42. In R.C.C. framed structures, the external walls shall not be less than 230 mm if in brick masonry or 150 mm, autoclaved cellular concrete block excluding plaster thickness as circulated under No CE/PD/11945/1 of 2.2.2006.
43. That the specification & design of Rain Water Harvesting scheme as per the State Govt.'s directives u/No TPB-1307/396/CR-124/2007/UID-11 dated 6<sup>th</sup> June 2007 shall not be submitted.
44. That the requisition of clause No. 45 and 46 of D.C. Regn. 97 shall not be complied with and records of quality of work, verification of report shall not be kept on site till completion of work.

45. That the Regd. Undertaking shall not be submitted by the Owner / Developer / Builder to sell the tenements / flats on carpet area basis only and to abide by the provisions of Maharashtra Ownership Flats (Regulation of the promotion of construction, sale management and transfer) Act (MOFA), amended up to date and the Indemnity Bond indemnifying the M.C.G.M. and its Officers from any legal complications arising due to MOFA will not be submitted.

46. That the registered Private Pest Control Agency for providing anti larval treatment at the construction site shall be appointed.

47. That the N.O.C. holder will have to execute agreement with MHADA / M.B.R. & R. Board in respect of surrender surplus built up area in accordance to the provisions of D.C. Regn. 33(7) as per 3<sup>rd</sup> schedule of MHADA Act 1976 within 30 days after approval of I.O.D. / plans by M.C.G.M. and prior issue of Commencement Certificate by M.C.G.M. on Rs.100/- stamp paper. The M.C.G.M. shall not grant Commencement Certificate or any further permission unless the agreement is duly executed between N.O.C. holder & MHADA / M.B.R. & R. Board and letter to that effect is issued by M.B.R. & R. Board

48. That the soil investigation will not be done & report thereof will not be submitted with structural design before entering for C.C.

(B) THE FOLLOWING CONDITIONS TO BE COMPLIED WITH BEFORE FURTHER C.C. OF SUPER STRUCTURE :

1. That the plinth dimensions shall not be got checked from this office before asking for further C.C. beyond plinth.
2. That the Structural stability certificate through Regd. Structural Engineer regarding stability of constructed plinth shall not be submitted before asking for C.C. beyond plinth.
3. That the repair of damaged road including storm water drain and shall not be constructed.


(C) THE FOLLOWING GENERAL CONDITIONS TO BE COMPLIED WITH BEFORE GRANTING O.C.C. TO ANY PART OF THE PROPOSED BUILDING :

1. That some of the drains will not be laid internally with C.I. Pipes
2. That the dust-bin will not be provided as per C.E.'s circular No. CE/51297/II of 26-6-1978
3. That the surface drainage arrangement will not be made in consultation with E.E. (SWD) or as per his remarks and a completion certificate will not be obtained and submitted before applying for occupation certificate B.C.C.
4. That 10'-0" wide paved pathway upto staircase will not be provided.
5. That the surrounding open spaces, parking spaces and terrace will not be kept open and un-built upon and will not be leveled and developed before.

- requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
6. That the name plate/Board showing Plot No., name of the building etc. will not be displayed at a prominent place.
  7. That carriage entrance shall not be provided.
  8. That the parking spaces shall not be provided as per D.C. Regulation No.36.
  9. That B.C.C. will not be obtained and I.O.D. and debris deposit etc. will not be claimed for refund within a period of 6 years from the date of its payment.
  10. That the N.O.C. from Inspector of Lifts, P.W.D., Maharashtra, will not be obtained and submitted to this office.
  11. That the Drainage completion certificate from (S.P.) (P&D) City for provision of Septic Tank/Soak pit will not be submitted.
  12. That the Drainage completion Certificate from A.E. (B.P.) City for house drain will not be submitted & got accepted.
  13. That every part of the building construction and more particularly overhead tank will not be provided as with the proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
  14. That final N.O.C. from Asstt Commissioner (Estates)/ MHADA C.F.O. Tise Authority shall not be submitted before asking for occupation permission.
  15. That the compliance of N.O.C. from H.E will not be made and certificate to that effect will not be submitted.
  16. That the Fresh property card in the name of the owner shall not be submitted.
  17. That the vermiculture bins for the disposal of wet waste as per design and specifications of organization or companies specialized in this field as per list furnished by Solid waste Management of M.C.G.M. shall not be provided.
  18. That the installation of Rain Water Harvesting scheme as per the State Govt.'s directives U/No. TPB-4307/396/CR-124/2007/UD-11 dated 6<sup>th</sup> June 2007 shall not be provided before applying for occupation permission.

**(D) THE FOLLOWING CONDITIONS TO BE COMPLIED WITH BEFORE B.C.C.**

1. That certificate under Section 270-A Of M.M.C. Act will not be obtained from H.E 's Department regarding adequacy of water supply.

  
 19.6.13  
 Executive Engineer  
 Building Proposals (City)

No. EB/CE/ 8245/17/13<sup>3</sup> /BS

JAY

### NOTES

- (1) The work should not be started unless objections are complied with.
- (2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work during the progress of the construction work.
- (3) Temporary permission on payment of deposit should be obtained any shed to house and store constructional purposes, Residence of workmen shall not be allowed on site. The temporary structure storing constructional material shall be demolished before submission of building completion certificate and a certificate signed by Architect submitted along with the building completion certificate.
- (4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- (5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the side drain.
- (6) The owners shall intimate the Hydraulic Engineer or his representative in Wards at least 15 days prior to date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presumed that Municipal tap water has been consumed on the construction and bills preferred against them accordingly.
- (7) The hoarding or screen wall for supporting the deposit of building materials shall be constructed before starting any work even though no materials may be expected to be stored in front of the property. The scaffolding, bricks, metal, sand, preps, debris, etc. should not be deposited over footpaths or public street by the architect/their contractors, etc. without obtaining prior permission from the Ward Officer of the area.
- (8) The work should not be started unless the manner in obviating all the objections is approved by this department.
- (9) No work should be started unless the structural design is approved.
- (10) The work above plinth should not be started before the same is shown to this office. Sub-Engineer and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- (11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road and footpath.
- (12) All the terms and conditions of the approved layout/sub-division under No. should be adhered to and complied with.
- (13) No Building/Drainage Completion Certificate will be accepted nor water connection granted (except for construction purposes) unless road is constructed to the satisfaction of the Municipal Commissioner as per provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions of sanction to the layout.
- (14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- (15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphaltting, lighting and drainage before submission of the Building Completion Certificate.
- (16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.
- (17) The surrounding open spaces around the building should be consolidated in Concrete having broken glass at the rate of 125 cubic meters per 10 sq. meters below payment.
- (18) The compound wall or fencing should be constructed clear of the road widening line with foundation level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting this work to prove the owner's holding.
- (19) No work should be started unless the existing structures proposed to be demolished are demolished.



