

Swati

This IOD is Issued subject to compliance of the provision of U.L. (C & R) Act. 1976.

Form 346  
68

in replying please quote No.  
and date of this letter.



MUNICIPAL CORPORATION OF GREATER MUMBAI

Intimation of Disapproval under Section 346 of the Mumbai  
Municipal Corporation Act, as amended up to date.

No. CHE/ES/0264/M/337(NEW)

Ct

2 APR 2010  
Municipal Office.

MEMORANDUM

CE/64341(BPIS)AMLE

To,

M/s. Tridhaastu Ventures Pvt. Ltd. C.A. to SRI SWATI CO-  
OPERATIVE HOUSING SOCIETY LTD.

VILLAGE BORLA, GOVANDI, MUMBAI 400088.

Mumbai

TRUE - COPY  
Per Karani & Sons Consultants Pvt. Ltd

Director

With reference to your Notice, letter No. 4310 dated 26/3/2010 and delivered on and the plans, Sections Specifications and description and further particulars and details of your buildings at

Proposed redevelopment of existing residential bids on plot bearing C.T.S No. 276, 276/1716 of Village Borla

furnished to me under your letter, dated I have to inform you that I cannot approve of the building or work proposed to be erected or executed, and I therefore hereby formally intimate to you, under Section 346 of the Mumbai Municipal Corporation Act as amended up to-date, my disapproval by reasons thereof :-

**A : CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE WORK BEFORE PLINTH C.C.**

- 1 That the commencement certificate under Sec.45/69(1)(a) of the M.R. & T.P. Act shall not be obtained before starting the proposed work.
- 2 That the compound wall shall not be constructed on all sides of the plot clear of road widening line with foundation below the bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C.Regulation No.38(27).
- 3 That the low lying plot shall not be filled up to reduced level of atleast 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc and will not be leveled, rolled, consolidated and sloped towards road side before starting the work.
- 4 That the specification for layout/D.P./or access roads/development of setback land shall not be obtained from Executive Engineer (Road Construction) before starting the construction work and the access and setback land shall not be developed accordingly including providing street lights and S.W.D., the completion certificate shall not be obtained from Executive Engineer (R.C.)/Executive Engineer (S.W.D.) E.S. before submitting building completion certificate
- 5 That the Licensed Structural Engineer will not be appointed, supervision memo as per appendix XI Regulation 5(3)(IX) will not be submitted by him.
- 6 That the structural design and calculations for the proposed work considering seismic forces as per I.S.Code Nos.456-2000, 13920 - 1993, 4326 and 1893 - 2002 as per circular u.no.CE/PD/11945/1 dated 2.2.2006 for existing building showing adequacy thereof to take up additional load will not be submitted by him.
- 7 That the C.C. shall not be asked unless payment of advance for providing treatment at construction site to prevent epidemics like Dengue, Malaria etc. is made to the Insecticide Officer of the concerned ward office and provision shall not be made as and when required by Insecticide Officer for inspection of water tanks by providing safe and stable ladder, etc. and requirements as communicated by the Insecticide Officer shall not be complied with.
- 8 That the carriage entrance shall not be provided before starting the work.

Executive Engineer Building Proposal  
(Eastern Suburbs.)

29 APR 2010

- 9 That the registered undertaking in prescribed proforma agreeing to demolish the excess area if constructed beyond permissible F.S.I. shall not be submitted before asking for C.C.
- 10 That the adequate & decent temporary sanitary accommodation will not be provided for construction workers on before starting the work.
- 11 That the documentary evidence regarding ownership, area and boundaries of holding is not produced by way of abstracts form the District Inspector of Land Records, extracts from City Survey Record and conveyance deed etc.
- 12 That separate P.R.Cards for each sub-divided plots, road etc.will not be submitted.
- 13 That the debris will not be removed before submitting the building completion certificate and requisite deposit will not be paid before starting the work towards faithful compliance thereof.
- 14 That the No Objection Certificate from Hydraulic Engineer for the proposed development will not be obtained and his requirements will not be complied with.
- 15 That the registered undertaking agreeing to form Co-op. Housing society will not be submitted before starting the work.
- 16 That the proposal will contravene the section 251 (A)(A) of the Mumbai Municipal Corporation Act.
- 17 That the society will not be formed & got registered and true copy of the registration of society will not be submitted.
- 18 That the remarks from Asst.Engineer, Water Works regarding location, size capacity of the suction tank, overhead storage tank for proposed and existing work willnot be submitted before starting the work and his requirements will not be complied with.
- 19 That the capacity of overhead tank will not be provided as per "P" form issued by department of Hydraulic Engineer and structural design to that effect admitted before requesting to grant commencement certificate
- 20 That the requirement of bye law 4(c) will not be complied with before starting the drainage work and in case Municipal sewer is not laid, the drainage work will not be carried on as per the requirement of Executive Engineer (Sewerage Project). Planning & completion certificate from him will not be submitted.
- 21 That the N.A. permission from the Collector of Bombay shall not be submitted.
- 22 That the development charges as per M.R.T.P.(amendment) Act 1992 will not be paid.
- 23 That a Janata Insurance Policy or policy to cover the compensation claims arising out of Workmen's Compensation Act 1923 will not be taken out before starting the work and will not be renewed during the construction.
- 24 That the remarks from geologist shall not be submitted.
- 25 That the debris generated /building material is dumped within a periphery of 50.00 mts from mangroves.
- 26 That the M.R. plan shall not be submitted before asking for C.C.
- 27 That the phase programme for infrastructure development will not be submitted and got approved and will not be developed as per phase programme.
- 28 That the N.O.C. from Insecticide Officer shall not be submitted
- 29 That the undertaking for paying additional premium due to increase in land rate as and when demanded shall not be submitted.
- 30 That the clearance certificate from assessment Department regarding upto date payment of Municipal taxes etc.will not be submitted
- 31 That the board mentioning the name of Architect/Owner shall not be displayed on site.
- 32 That the debris management plan shall not be submitted to S.W.M. Department
- 33 That the copy of Intimation of Disapproval conditions & other layout or sub division conditions imposed by the Corporation in connection with the developmental site shall not be given to the would be purchaser and also displayed at site.
- 34 That the regular/sanctioned/ proposed lines and reservations will not be got demarcated at site through A.E.(Survey)/E.E.(T&C)/E.E.(D.P.)/D.I.L.R.before applying for C.C.
- 35 That the agreement with existing tenants along with the plans for demolition of their tenements for acceptance of alternate accommodation will not be submitted before C.C.
- 36 That the registered undertaking and additional copy of plan shall not be submitted for agreeing to hand over the setback land free of compensation and that the setback handing over certificate

Executive Engineer Building Proposal

29 APR 2010

will not be obtained from Ward Officer and the ownership of the setback land will not be transferred in the name of M.C.G.M.

- 37 That the consent letter from existing tenants for proposed additions/alterations in their tenement will not be submitted before C.C.
- 38 That the Indemnity Bond indemnifying the Municipal Corporation for damages, risks, accidents, etc. to the occupiers and an undertaking regarding no nuisance will not be submitted before C.C / starting the work.
- 39 That the existing structure proposed to be demolished will not be demolished or necessary phase programme with agreement will not be submitted and got approved before C.C
- 40 The N.O.C from M/S Reliance Energy will not be complied with before occupation certificate/B.C.C.
- 41 That the qualified registered site supervisor through architect/structural engineer will not be appointed before applying for C.C. & his name and licence No. duly revalidated will not be submitted.
- 42 That the no dues pending certificate will not be submitted from the concerned Asst. Engineer, Water Works department before C.C.
- 43 That adequate care in planning, designing and carrying out construction will not be taken in the proposed building to provide for the consequence of settlement of floors and plinth filling etc.
- 44 That adequate care will not be taken to safeguard the trees existing on the plot while carrying out construction work & remarks from S.G. shall not be submitted.
- 45 That the notice under Sec.347 (1)(a) of the Mumbai Municipal Corporation Act will not be sent for intimating the date of commencement of the work.
- 46 That this office will not be intimated in prescribed proforma for checking the opens spaces and building dimensions as soon as the work upto plinth is completed.
- 47 That the Demarcation of Public Housing and Municipal Housing <sup>residential</sup> shall not be submitted.
- 48 That the requirements as per circular no. CE/PD/12387 of 17.3.2005 shall not be complied with during the execution of work.

**B : CONDITIONS TO BE COMPLIED WITH BEFORE FURTHER C.C.**

- 1 That the N.O.C. from Civil Aviation Department will not be obtained for the proposed height of the building.

**C : GENERAL CONDITIONS TO BE COMPLIED WITH BEFORE O.C.**

- 1 That the requisitions of clause No.45 & 46 of D.C.R.91 shall not be complied with.
- 2 That the provision for rain water harvesting as per design prepared by approved consultant in the field shall not be made to the satisfaction of Municipal Commissioner.
- 3 That the Vermiculture bins for disposal of wet waste as per the design and specification of Organisations / individuals specialized in this field, as per the list furnished by Solid Waste Management Department of MCGM, shall not be provided to the satisfaction of Municipal Commissioner.
- 4 That some of the drains will not be laid internally with C.I. pipes.
- 5 That the dust bin will not be provided as per C.E.'s circular No. CE/9295/11 of 26.6.1975.
- 6 That the surface drainage arrangement will not be made in consultation with Executive Engineer (S.W.D.) or as per his remarks and a completion certificate will not be obtained and submitted before applying for occupation certificate.
- 7 That 10 ft wide paved pathway upto staircase will not be provided.
- 8 That the surrounding open spaces, parking spaces and terrace will not be kept open and unbuilt upon and will not be levelled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
- 9 That the name plate/board showing plot No. name of the building etc. will not be displayed at a prominent place before O.C.C./B.C.C.
- 10 That the parking spaces shall not be provided as per D.C. Regulation No.36.
- 11 That B.C.C. will not be obtained and I.O.D. and debris deposit etc. will not be claimed for refund within a period of 6 years from the date of its payment.
- 12 That the provision will not be made for making available water for flushing and other non-potable purposes through a system of borewell and pumping that water through a separate overhead tank.

Executive Engineer Building Proposed

- tank which will be connected to the drainage system and will not have any chances of mixing with the normal water supply of the Corporation.
- 13 That one set of plans mounted on canvas will not be submitted.
  - 14 That the certificate to the effect that the licensed surveyor has effectively supervised the work and has carried out tests for checking leakages through sanitary blocks, termite, fixtures, joints in drainage pipes etc. and that the workmanship is found very satisfactory shall not be submitted.
  - 15 That the certificate from Lift Inspector regarding satisfactory installation and operation of lift will not be submitted.
  - 16 That the federation of flat owners of the sub-division/layout for construction and maintenance of the infrastructure will not be formed.
  - 17 That the adequate provision for post-mail boxes shall not be made at suitable location on ground floor /stilt.
  - 18 That the every part of the building construction and more particularly, overhead tank will not be provided with a proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
  - 19 That the final NOC from S.G. shall not be submitted.
  - 20 That the infrastructural works such as; construction of handholes/manholes, ducts for underground cables, concealed wiring inside the flats/rooms, rooms/space for telecom installations etc. required for providing telecom services shall not be provided.

**D : CONDITIONS TO BE COMPLIED WITH BEFORE B.C.C.**

- 1 That certificate under Section 270-A of the Bombay Municipal Corporation Act will not be obtained from H.E, s department regarding adequacy of water supply.
- 2 That the ownership of the recreation space/swimming pool /Club House shall not vest by provision in a deed of conveyance in all the property owners on account of whose holding the R.G./Swimming Pool Club House is assigned.

*[Signature]*  
Executive Engineer Building Proposal  
(Eastern Suburbs.)

20 APR 2018

- ( ) That proper gutters and down pipes are not intended to be put to prevent water dropping from the leaves of the roof on the public street.
- ( ) That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the day of but not so as to contrivance any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time in force. Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

—*sd*—  
Executive Engineer, Building Proposals,  
Zone, —*ss*— Wards.

### SPECIAL INSTRUCTIONS

1. THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.
2. Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 346 of the said Act.
3. Under Byelaw, No. 8 of the Commissioner has fixed the following levels :-  
"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be—  
  - a) Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be laid in such street
  - b) Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.) of such building.
  - c) Not less than 92 ft. (28.05 m) above Town Hall Datum.
4. Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.
5. Your attention is further drawn to the provision of Section 353-A about the necessary of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance under Section 471 if necessary.
6. Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.
7. One more copy of the block plan should be submitted for the Collector, Mumbai Suburban District.
8. Necessary permission for Non-agricultural use of the land shall be obtained from the Collector Mumbai Suburban District before the work is started. The Non-agricultural assessment shall be paid at the site that may be fixed by the Collector, under the Land Revenue Code and Rules there under.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.

*M. S. S.*  
Executive Engineer Building Propos.  
(Eastern Suburban.)

NOTES

- 1) The work should not be started unless objections are complied with
- 2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
- 3) Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.
- 4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- 5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the road side drain.
- 6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presume that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.
- 7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or public street by the owner/ architect /their contractors, etc without obtaining prior permission from the Ward Officer of the area.
- 8) The work should not be started unless the manner in obviating all the objection is approved by this department.
- 9) No work should be started unless the structural design is approved.
- 10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- 11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.
- 12) All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.
- 13) No Building /Drainage Completion Certificate will be accepted non water connection granted (except for the construction purpose) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.
- 14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- 15) The access road to the full width shall be constructed in water bound macadam before

*M. K. S. S.*  
Executive Engineer Building Propos.  
(Eastern Suburbs.)  
29.4.2010

CE/6484/BPES/A m/E 29 APR 2010

commencing work and should be complete to the satisfaction of Municipal Commissioner including asphaltting lighting and drainage before submission of the Building Completion Certificate

Flow of water through adjoining holding or culvert if any should be maintained unobstructed

The surrounding open spaces around the building should be consolidated in Concrete having broken glass pieces at the rate of cubic meters per square meters below pavement

The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to protect the owner's holding

No work should be started unless the existing structures proposed to be demolished are demolished

The intimation of disapproval is given conclusively for the purpose of enabling you to proceed further with the arrangements of obtaining objection Certificate from the Housing Commissioner under section 14 of the Act and in the event of your proceeding with the work either without an intimation about commencing the work under section 14 or without starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this intimation of disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under section 14 of the Maharashtra Regional and Town Planning Act of the Town Planning Act will be withdrawn

If it is proposed to demolish the existing structures by negotiations with the tenant under the circumstances the work as per approved plans should not be taken up in hand unless the Civil Engineer is satisfied with the following

- i) Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the areas in occupation of each
- ii) Specifically signed agreement between you and the existing tenants that they are willing to avail or the alternative accommodation in the proposed structure at standard rent
- iii) Plans showing the phased programme of constructions has to be duly approved by this office before starting the work so as not to contravene at any stage of construction the development control rules regarding open spaces light and ventilation of existing structure

In case of extension to existing building blocking of existing windows of rooms derailing light and its from other sides should be done first starting the work

In case of additional floor no work should be start or during monsoon which will cause water leakage and consequent nuisance to the tenants staying on the floor below

The bottom of the overhead storage work above the finished level of the terrace shall not be more than one metre

The work should not be started above first floor level unless the objection Certificate from the Civil Engineering authorities where necessary is obtained

It is to be understood that the foundations must be excavated down to hard soil

The positions of the manholes and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building

The water arrangement must be carried out in strict accordance with the Municipal requirements

No new well tank pond cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai as required in section 14 of the Municipal Corporation Act

*[Signature]*  
Executive Engineer Building Propose  
(Eastern Suburb)

- 30) All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbit pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perforations each not exceeding 1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible by providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.
- 31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
- 32) a Louvres should be provided as required by ByeLaw No. 5 (b)  
b Lintels or Arches should be provided over Door and Windows opening  
c The drains should be laid as require under Section 234-1(a)  
d The inspection chamber should be plastered inside and outside.
- 33) If the proposed additional is intended to be carried out on old foundations and structures, you will do so as your own risk.

CEI 6434/BPESIA/ME

20 APR 2010

Architect

*Mehar*  
24/06/2010  
Executive Engineer, Building Proposals  
Zones ..... wards.