

उपप्रमुख अभियंता इमारत (प्रस्ताव) प.उ.-दोन
 महापालिका इमारत, सी विंग, संस्कृती कॉम्प्लेक्स,
 १० फुट डी पी रोड, सेंट लॉरेन्स शाळेजवळ,
 कादिवला (पूर्व), मुंबई-४०००१०
 in replying please quote No.
 and date of this letter.

THIS I.O.D./C.C. IS ISSUED SUBJECT
 TO THE PROVISIONS OF URBAN LAND
 CEILING AND REGULATIONS ACT 1976

346
 Form -----
 88

**Intimation of Disapproval under Section 346 of the Mumbai
 Municipal Corporation Act, as amended up to date.**

CHE/A-4925/BP(W.S)/AR 22 NOV 2010
 No. E.B./CE/ BS/A of 200 - 200

MEMORANDUM
 Owner,

Shri Sai Vishram C.H.S. Ltd.

Municipal Office,
 Mumbai200

With reference to your Notice³³⁷ letter No. ⁹⁰⁵⁰..... dated ²⁹⁻¹⁰⁻²⁰¹⁰ 200 and delivered on
 200 and the plans, Sections Specifications and Description and further particulars and
 details of your buildings at Proposed building on plot bearing C.T.S. No. 772/A furnished
 of Village Eksar at Kandarpada, Dahisar (East), Mumbai.
 to me under your letter, dated 200..... I have to inform you that I cannot approval of the building
 or work proposed to be erected or executed, and I therefore hereby formally intimate to your, under Section 346 of
 the Bombay Municipal Corporation Act as amended upto-date, my disapproval by thereof reasons :-

**A - CONDITIONS TO BE COMPLIED WITH BEFORE STARTING
 THE WORK/BEFORE PLINTH C.C.**

1. That the C.C. under Sec. 44\69 (1) (a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
2. That the compound wall is not constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C.Reg.No.38(27).
3. That the low lying plot will not be filled up to a reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders etc. and will not be levelled, rolled, consolidated and sloped towards road side, before starting the work.